STORM WATER INSPECTION FORM				
Date of Inspection			Inspector's Initials	
Inspection Location (Building Number)				
Inspection Items*	Area/Equipment Present?	Improvements Needed		Comments
Aboveground/Underground Storage Tank	☐ Yes ☐ No	☐ Yes ☐ No		
Drum Storage Area	☐ Yes ☐ No	☐ Yes ☐ No		
Storage Yard	☐ Yes ☐ No	☐ Yes ☐ No		
Erosion	□ Yes □ No	☐ Yes ☐ No		
Materials Handling/Fueling Area	☐ Yes ☐ No	☐ Yes ☐ No		
Vehicle/Equipment Washing Area	☐ Yes ☐ No	☐ Yes ☐ No		
Other Area	☐ Yes ☐ No	☐ Yes ☐ No		
Date of Inspection			Inspector's Initials	
Inspection Location (Building Number)				
Inspection Items*	Area/Equipment Present?	Improvements Needed		Comments
Aboveground/Underground Storage Tank	☐ Yes ☐ No	☐ Yes ☐ No		
Drum Storage Area	☐ Yes ☐ No	☐ Yes ☐ No		
Storage Yard	☐ Yes ☐ No	☐ Yes ☐ No		
Erosion	☐ Yes ☐ No	☐ Yes ☐ No		
Materials Handling/Fueling Area	☐ Yes ☐ No	☐ Yes ☐ No		
Vehicle/Equipment Washing Area	☐ Yes ☐ No	☐ Yes ☐ No		
Other Area	☐ Yes ☐ No	☐ Yes ☐ No		
Date of Inspection			Inspector's Initials	
Inspection Location (Building Number)				
Inspection Items*	Area/Equipment Present?	Improvements Needed		Comments
Aboveground/Underground Storage Tank	□ Yes □ No	☐ Yes ☐ No		
Drum Storage Area	☐ Yes ☐ No	☐ Yes ☐ No		
Storage Yard	☐ Yes ☐ No	☐ Yes ☐ No		
Erosion	☐ Yes ☐ No	☐ Yes ☐ No		
Materials Handling/Fueling Area	☐ Yes ☐ No	☐ Yes ☐ No		
Vehicle/Equipment Washing Area	☐ Yes ☐ No	☐ Yes ☐ No		
Other Area	☐ Yes ☐ No	☐ Yes ☐ No		

INSPECTION CHECKLIST

Inspection Checklist for ASTs/USTs: Monthly and after significant rainfall

- No leaking, cracks, or detrimental corrosion of aboveground fixtures
- Materials available near each tank to clean up small spills, as necessary
- Tanks are properly labeled as identified by EEOH (i.e. contents, hazard)
- Containment bypass valves properly sealed/closed and locked when not in use
- Inspect the concrete containment structure or the interior space of a double-walled storage tank to confirm no accumulation of oil is present
- No visible contamination (sheen) on water collected in containment prior to discharging any storm water from the containment basin
- Spill prevention controls and containment area in good condition
- No sign of spillage from material handling operations
- Out-of-service tanks have been drained, proper signage is posted, and piping is valved/closed off
- Erosion prevention at the containment area drain valve is satisfactory
- · Overfill prevention controls for tank are in place and in working order
- Discharge any uncontaminated storm water collected in the containment basin
- Active containment (drip pans, booms, and sorbent materials) is provided for portable tanks

Inspection Checklist for Drum Storage Areas: Monthly

- Containers are protected from weather and provide secondary containment when stored outside
- · Containment system is in good condition
- · Containment valves are closed
- No liquid or debris in secondary containment (if liquid is in containment area, check container for leaks, collect liquid and debris from containment area as necessary for proper disposal)
- · Containers properly labeled to identify contents and hazards
- · Storage area is neat and orderly
- No evidence of spillage from material-handling operations, clean up spills, and properly dispose of spillage
- Containers are in good condition, properly labeled, and closed/sealed when not in use
- · Identify and replace damaged pallets
- · Remove and replace damaged containers

Inspection Checklist for Drum Storage Areas: Monthly (continued)

- Materials available at storage areas to clean up small spills as necessary
- Erosion and sedimentation control measures in place
- Drip pan not overflowing with liquid or debris
- · Chemical storage cabinets are closed and have no visible leaks

Inspection Checklist for Storage Yards: Monthly

- No sign of leakage from stored equipment
- No visible sign of contamination on equipment in storage yard
- Only store material for storage yard intended use (i.e., no waste drums in parts lay-down yards)
- · Materials and equipment stored neatly
- Stored, unused, or abandoned equipment is drained of oil, fuel, sludge, or chemicals; are disconnected; and an "out of service" sign with date is placed on the equipment
- · Erosion prevention is satisfactory

Inspection Checklist for Erosion Control: Monthly

- No signs of excessive erosion
- · Erosion controls are effective and in good condition
- No sediment buildup in storm water structures (inlets, ditches)

Inspection Checklist for Materials Handling/Fueling Areas: Monthly

- No sign of spillage from material loading and unloading operations and stop activities and implement spill control activities if spillage occurs
- Effective measures are in place to prevent contact with storm water during material handling operations
- Materials available at site to clean up small spills as necessary
- Spill and overflow protection equipment works properly
- Curb the area around the loading area to direct run-on away from the unloading area
- Confirm wheel chocks present and in good condition

Inspection Checklist for Vehicle and Equipment Washing: Monthly

- Vehicle washing confined to appropriate areas
- Catch basins in wash area maintained (not clogged with sediment or debris)
- · Erosion prevention is satisfactory